

803-2537

S.A. HOME COMFORT CENTRE LTD.1860 10th Ave. SW, Box 64, Salmon Arm, BC V1E 4N2
PH. (250) 804-4328 • FAX. (250) 804-2665**PROPOSAL**

DATE <u>JAN 26/07</u>		HOME PHONE _____	
CUSTOMER <u>MURDOCH</u>		WORK _____	
INSTALL ADDRESS: <u>3901 60 ST NW</u> <u>Salmon Arm.</u>		MAILING ADDRESS _____	
PREPARED BY	ORDERED BY	Terms	Tax ID
		DUE UPON INSTALLATION	GST 852845148RT0001
Qty	Description of Service	Investment	
	CARRIER FURNACE APPEARS TO BE LEAKING CONDENSATE FROM HEAT EXCHANGER. LIFE SPAN WILL BE REDUCED CONSIDERABLY. (ESTIMATE 2-3 YEARS)		
	REPLACE WITH LENNOX G61 V 94+ EFF. FURNACE, 2 STAGE, VARIABLE SPEED BLOWER - 90,000 BTU -		
	- WILL ADD 2 EXTERNAL FILTER RACKS TO MAKE FILTERS MORE EASY ACCESSIBLE. (150 ⁰⁰ VALVE).		
	QUALIFIES FOR 200 ⁰⁰ LENNOX REBATE BEFORE JAN 31/07		
	+ TERASEN GAS CREDIT OF 350 ⁰⁰ BEFORE MARCH 31.		
	WILL DEDUCT CLEANING BILL IF BEFORE JAN 31. TOTAL TO SAVE ABOUT \$800 ⁰⁰		
Anticipated installation date _____		Total Investment	4599 -
Investment Authorization _____		PST	LESS REBATES ETC.
WARRANTY - TEN YRS PARTS. 20 YRS HEAT EXCHANGER.		GST	275.94
		DEPOSIT	
		TOTAL DUE	

S.A. HOME COMFORT CENTRE LTD.

1860 10th Ave. SW, Box 64, Salmon Arm, BC V1E 4N2
PH. (250) 804-4328 • FAX. (250) 804-2665

Ask about our 100% 1-yr
Satisfaction Guarantee

HC PLUS CUSTOMER

☐ YES

☐ NO

Date

JAN 26/07 Technician No. STEVE

Reason For Today's Call:

Furnace PTV

☒ Work Complete

☐ Work Incomplete

☐ Outstanding Proposal

☐ 20 Residential Service

☐ 23 RNC

☐ 50 IAQ

☐ Workmanship Warranty

☐ 21 Residential Replacement

☐ 10 Commercial Service

☐ Extended Warranty

☐ Warranty

☒ 22 Maintenance

☐ 30 Fireplace

Work Performed: Filter Size 16x25 x 1 Filter Type DUST REDUCTN.

Heating Appliance

☒ Vent to Code

☒ Checked I.D. Coil

☐ Subcool

☒ Check T-stat Operation

☒ Blue Temp 81

☐ Checked Motors

☐ OA Temp

☐ Set Heat Anticipator

☐ Lubricate Motor/Bearings

☐ Comp. Amps

☐ Head PSIG

☒ Checked Air Filter

☒ Checked Belts

☐ Cond., Mtr. Amps

☐ Suction PSIG

☒ Checked Burners

☒ Checked Pulleys

☐ Blwr Mtr Amps

☐ Check for Refrigeration Leaks

☒ Checked Heat Exch.

☒ A/C Heat Pump

☐ Superheat

☐ Adj. Refrigeration Charge

☒ Checked Pilot

☒ Checked Contactor

☐ RA

☐ Lbs. Oz.

☒ Checked Safety Controls

☒ Checked Condensate

☐ SA

☐ Clean Equipment

☒ Checked Electrical

☐ Checked O.D. Coil

☐ ΔT

☐ Exteriors

Description of Work Performed:

COMPLETE SERVICE: DISASSEMBLED &

(CLEANED) BLOWN + MOTION.

CLEANED BURNER + FLAME ROD,

INSPECTED IGNITOR.

CHECKED AIR INTAKE OR

CREATED CONDENSATE LINES.

Technician Recommendations:

INSPECTED HEAT EXCHANGER -

CONSIDERABLE CONDENSATE LEAK APPEARS

TO BE FROM HEAT EXCHANGER.

EQUIPMENT MAKE MODEL SERIAL

1. FURNACE CARRIER 58MAXA120-10120

2.

3.

4.

5.

Dispatch

Cust. #

P.O. #

Customer Name

MURDOCH

Bill To:

Address

3901 60 ST NW

Address

City/Postal

SANED AMN

City/Postal

H. Phone

832-0963

W. Phone

Qty.

Repair Code

Description

Price

Plus Price

1

04900101

Dispatch Fee

✓

1

Furnace PTV

98-

✓

1

04900201

Misc. Supplies, Environmental Fee

✓

ALL WORK IS COD - Please Pay Technician

HC Plus

PAID BY

☐ CASH

DEFENSE # 635

OTHER

☐ VISA

☐ MC

98-

SUB-TOTAL

5-88

Authorization Code

GST #852845148RT0001

AMOUNT DUE

\$103.88

Card No.

Name on Card

Exp.

Thank You!

Authorization of work

Signature

Signature

I hereby acknowledge the satisfactory completion of the above described work.

Technician's Signature

See Reverse Side For Terms

RESIDENTIAL & COMMERCIAL

S.A. HOME COMFORT CENTRE LTD.

1860 10th Ave. SW, Box 64, Salmon Arm, BC V1E 4N2
PH. (250) 804-4328 • FAX. (250) 804-2665

Ask about our 100%
Satisfaction Guarantee

No 7120

HC PLUS CUSTOMER ☐ YES ☐ NO Date <u>Nov 26 9</u> Technician No. <u>109</u>			
Reason For Today's Call: <u>F/Pune got repair</u>			
☐ Work Complete ☐ Work Incomplete ☐ Outstanding Proposal			
☐ 20 Residential Service ☐ 23 RNC ☐ 50 IAQ ☐ Workmanship Warranty			
☐ 21 Residential Replacement ☐ 10 Commercial Service ☐ Extended Warranty ☐ Warranty			
☐ 22 Maintenance ☐ 30 Fireplace ☐			
Work Performed: Filter Size <u>X</u> Filter Type <u>X</u>			
Heating Appliances ☐ Vent to Code P <u>F</u> ☐ Subcool ☐ OA Temp ☐ Head PSIG			
☐ Check T-stat Operation ☐ Lubricate Motor/Bearings ☐ Cond., Mtr. Amps ☐ Suction PSIG			
☐ Set Heat Anticipator ☐ Checked Belts ☐ Blwr Mtr Amps ☐ Check for Refrigeration Leaks			
☐ Checked Air Filter ☐ Checked Pulleys ☐ Superheat ☐ Adj. Refrigeration Charge			
☐ Checked Burners ☐ A/C Heat Pump ☐ RA ☐ Lbs. ☐ Oz.			
☐ Checked Heat Exch. ☐ Checked Contactor ☐ SA ☐ Clean Equipment			
☐ Checked Pilot ☐ Checked Safety Controls ☐ Checked O.D. Coil ☐ ΔT ☐ Extensors			
Description of Work Performed: <u>Clean F/P's + Check</u>			
<u>Flame + thermostat ok</u>			
<u>micro switch gone</u>			
Technician Recommendations: <u>Need to order Micro Switch</u>			
<u>+ a Quote on 50us power vented Rheem - Pump</u>			
EQUIPMENT	MAKE	MODEL	SERIAL
1. F/P north	Flame	NF 34	16A 001541
2.			
3.			
4. Furnace	DV 34LN		081116390
5.			

Dispatch <u>25171022</u> Cust. # <u>2517</u> P.O. # <u></u>				
Customer Name <u>Elizabeth Muckack</u> Bill to:				
Address <u>3901 60th St NW</u>				
City/Postal <u>Salmon Arm BC</u>				
H. Phone <u>832-0963</u> W. Phone <u></u>				
Qty.	Repair Code	Description	Price	Plus Price
1	04900101	Dispatch Fee		
		<u>Diagnostic</u>		<u>89.00</u>
		<u>F/P tune up</u>		<u>98.</u>
		<u>1 stat + PLASCO ignitor</u>		<u>125.00</u>
1	04900201	Misc. Supplies, Environmental Fee		
ALL WORK IS COD - Please Pay Technician				
PAID BY ☐ CASH ☒ CHEQUE# <u>105</u>		HC Plus		
☐ VISA ☐ MC		OTHER		
Authorization Code <u>GST #852845148RT0001</u>		SUB-TOTAL <u>312.00</u>		
Card No. <u></u>		AMOUNT DUE <u>\$330.72</u>		
Name on Card <u></u> Exp. <u></u>		Authorization of work <u></u>		

Thank You!

LEMMAX

RESIDENTIAL & COMMERCIAL

See Reverse Side For Terms

I hereby acknowledge the satisfactory completion of the above described work.

Technician's Signature [Signature]


SIGNATURE